

**NOTES:**

1. BLOW-OFF ASSEMBLY TO BE SUPPLIED BY GIL INDUSTRIES (MODEL: SLIM LINE 2" FLUSHING HYDRANT) OR APPROVED EQUAL.
2. A BLOW-OFF IS TO BE USED ON PIPE SIZES 10" IN DIAMETER OR LESS.
3. A FIRE HYDRANT IS TO BE USED AS A BLOW-OFF ASSEMBLY FOR PIPE SIZES 12" OR GREATER.
4. PLASTIC COATED 10 GAUGE SOLID COPPER TRACER WIRE TO BE ATTACHED WITH PLASTIC STRAPPING EVERY 10 FEET OF LENGTH. WIRE TO BE LOOPED THROUGH VALVE BOX AND EXTEND 12 INCHES ABOVE FINISHED GRADE AND COILED BACK INTO VALVE BOX.

## **BLOW-OFF ASSEMBLY**

NOT TO SCALE

REFERENCE 200,801	CATEGORY WATER DISTRIBUTION	DATE 12/10	SHEET No. 2 OF 2	DETAIL No. WD_05
----------------------	--------------------------------	---------------	---------------------	---------------------