



NOTES:

1. DUAL SERVICE REQUIRES PRIOR LOCALITY APPROVAL.
2. CONTRACTOR SHALL USE APPROVED BENDING TOOLS WHEN INSTALLING COPPER PIPE.
3. ALL DUCTILE IRON MAINS, SIX INCHES IN DIAMETER AND LARGER, MAY BE TAPPED WITHOUT SADDLES. WHERE PVC MAINS ARE PERMITTED BY LOCALITIES, THE CONNECTION TO A PVC MAIN MUST BE MADE WITH A TAPPING SADDLE. TAPPING SADDLES SHALL BE AS SPECIFIED IN SECTION 200 AND SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURERS SPECIFICATIONS. ALL SADDLES TO BE STAINLESS STEEL OR EPOXY COATED.
4. INSTALL METER BOX BETWEEN THE CURB AND GUTTER AND THE SIDEWALK. METER BOXES SHALL NOT BE INSTALLED IN DRIVEWAY.

**SINGLE & DUAL
SERVICE CONNECTIONS**

NOT TO SCALE

REFERENCE	CATEGORY	DATE	SHEET No.	DETAIL No.
200,801	WATER DISTRIBUTION	6/16	1 OF 1	WD_01